



Republic of the Philippines  
Department of Health  
**REGION 1 MEDICAL CENTER**  
Arellano Street, Dagupan City  
**BAC Office**  
Tel No.: (075) 523-18-65  
Telefax: (075) 523-41-03  
[r1mcsbac2012@gmail.com](mailto:r1mcsbac2012@gmail.com)

*DAE*

## NOTICE OF AWARD

May 3, 2022

**JOSE MARAMBA JR.**  
Authorized Representative  
**ALPHIN TRADING & CONSTRUCTION**  
Maningding, Sta. barbara, Pangasinan

**Dear Sir:**


This is to inform you that the **EQUIPMENT REPAIR**, as per **BAC Resolution No. AMP-NP-050A s,(4) 2022** through the use of Alternative Mode of Procurement, specifically **Small Value Procurement** is hereby awarded to you at a Contract Price equivalent to **Eighty-Nine Thousand Six Hundred Twenty Pesos (P 89,620.00)**.

ITEM NO.	ITEM & DESCRIPTION	QTY.	UNIT	UNIT PRICE	TOTAL PRICE
2	Equipment Repair, O-2 ( Estimated Cost Range from 45,001.00 To 50,000.00 ) ( 9303 ) Area/Section: OPD Building Room: Minor OR Waiting Area Brand: DAIKIN Model: FVQ100CVEB Serial Number: G003113 Type: Cabinet Reason for Repair: Defective Indoor PCB Assembly, Defective Outdoor Sensor Remarks: For Repair	1	LOT	49,800.00	49,800.00
3	Equipment Repair, N-5 ( Estimated Cost Range from 35,001.00 to 40,000.00 ) ( 9302 ) Area/ Section: Annex Binloc Room: OR Room #8 Brand Daikin Model: AVA100AMVM Serial No.: G000306 Type Cabinet Reason for Repair: Defective Indoor PCB Assembly Remarks: For Repair	1	LOT	38,820.00	38,820.00
<b>GRAND TOTAL</b>					<b>P 89,620.00</b>


You are therefore required to deliver the above items within the period stated in the Request for Quotation


You have submitted, Failure to comply shall constitute a sufficient ground for **cancellation of this award.**

Approved By:

  
**JOSEPH ROLAND O. MEJIA, MD, FPSMS, MBAH, MPA, DHSM, CESE**  
Medical Center Chief II

Conforme:

  
\_\_\_\_\_  
(Name of Representative of Bidder)

  
\_\_\_\_\_  
(Authorized Signature)

\_\_\_\_\_  
(Date)

R1MC-MCC-BAC-FRM-021

REV.0/25-JULY-2013